

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB12
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	24,00	2.459	102,46	---	---	---	0:22	194,27	20,00
02.08.24	24,00	2.461	102,54	---	---	---	23:28	194,26	20,01
03.08.24	23,44	2.397	102,27	---	---	---	18:37	194,30	19,97
04.08.24	0,00	0	---	23:59	199,65	14,62	---	---	---
05.08.24	0,00	0	---	5:04	199,78	14,49	---	---	---
06.08.24	3,15	325	103,12	7:39	200,00	14,27	9:19	195,30	18,98
07.08.24	0,67	69	102,31	5:41	199,74	14,53	---	---	---
08.08.24	0,00	0	---	15:27	199,91	14,36	---	---	---
09.08.24	3,36	341	101,53	3:10	199,94	14,33	22:13	195,44	18,83
10.08.24	5,88	600	102,09	19:53	199,87	14,40	1:10	195,34	18,94
11.08.24	3,62	375	103,73	9:57	199,92	14,36	12:01	195,44	18,83
12.08.24	10,07	1.046	103,87	3:34	200,04	14,23	23:24	194,97	19,30
13.08.24	22,34	2.325	104,09	11:39	199,69	14,58	11:55	194,37	19,90
14.08.24	24,00	2.459	102,46	---	---	---	23:07	194,44	19,84
15.08.24	24,00	2.456	102,33	---	---	---	19:02	194,30	19,97
16.08.24	24,00	2.478	103,25	---	---	---	0:00	194,57	19,70
17.08.24	24,00	2.476	103,17	---	---	---	23:43	194,59	19,68
18.08.24	24,00	2.473	103,04	---	---	---	17:45	194,53	19,75
19.08.24	24,00	2.450	102,08	---	---	---	21:08	194,34	19,94
20.08.24	23,76	2.426	102,12	---	---	---	22:29	194,34	19,94
21.08.24	24,00	2.445	101,88	---	---	---	21:16	194,24	20,03
22.08.24	24,00	2.441	101,71	---	---	---	23:38	194,27	20,01
23.08.24	20,60	2.090	101,46	23:53	198,99	15,28	19:28	194,17	20,11
24.08.24	0,00	0	---	21:31	199,50	14,77	---	---	---
25.08.24	0,00	0	---	5:35	199,80	14,47	---	---	---
26.08.24	1,78	183	102,71	3:20	199,69	14,59	22:54	195,25	19,02
27.08.24	2,08	214	102,84	7:09	200,00	14,27	9:12	195,28	18,99
28.08.24	0,85	87	102,72	8:54	199,67	14,60	---	---	---
29.08.24	14,02	1.444	102,98	0:44	199,71	14,56	23:43	194,51	19,76
30.08.24	15,15	1.542	101,80	23:11	199,27	15,01	12:36	194,37	19,91
31.08.24	0,00	0	---	23:33	199,58	14,69	---	---	---
Σ	390,76	40.062							
Mittelwert	12,61	1.292	102,52		199,72	14,55		194,65	19,62
Minimum	0,00	0	101,46		198,99	14,23		194,17	18,83
Maximum	24,00	2.478	104,09		200,04	15,28		195,44	20,11

Meßpunkthöhe (MP): 214,27 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB13
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	11,81	1.559	131,97	15:15	200,30	13,93	0:17	195,49	18,73
02.08.24	11,02	1.471	133,47	10:06	200,33	13,89	23:19	195,59	18,64
03.08.24	9,89	1.334	134,86	9:45	200,34	13,89	23:52	195,65	18,57
04.08.24	22,48	3.249	144,54	---	---	---	0:17	195,43	18,79
05.08.24	23,53	3.373	143,35	---	---	---	19:59	195,78	18,44
06.08.24	22,30	3.157	141,58	---	---	---	15:55	195,78	18,44
07.08.24	24,00	3.387	141,13	---	---	---	19:05	195,68	18,54
08.08.24	22,95	3.219	140,25	15:25	200,80	13,42	0:00	195,69	18,54
09.08.24	23,47	3.384	144,20	---	---	---	12:12	195,89	18,33
10.08.24	24,00	3.479	144,96	---	---	---	1:17	195,99	18,23
11.08.24	24,00	3.498	145,75	---	---	---	0:00	196,08	18,15
12.08.24	22,39	3.207	143,24	---	---	---	1:59	196,11	18,11
13.08.24	18,26	2.457	134,54	11:33	201,13	13,09	11:59	195,53	18,69
14.08.24	14,38	1.920	133,48	9:33	200,80	13,42	20:12	195,77	18,45
15.08.24	12,97	1.711	131,89	9:17	200,40	13,83	18:57	195,60	18,62
16.08.24	0,00	0	---	23:27	200,73	13,49	---	---	---
17.08.24	2,85	385	135,33	17:52	200,82	13,40	---	---	---
18.08.24	6,17	847	137,26	10:51	200,77	13,45	17:40	196,09	18,13
19.08.24	13,41	1.774	132,30	6:32	200,64	13,58	21:03	195,73	18,50
20.08.24	12,51	1.704	136,21	8:24	200,50	13,73	22:25	195,57	18,65
21.08.24	14,48	1.944	134,24	5:03	200,43	13,80	13:34	195,49	18,73
22.08.24	14,08	1.868	132,69	8:30	200,34	13,88	23:30	195,62	18,60
23.08.24	16,12	2.167	134,44	5:38	200,22	14,00	21:59	195,32	18,90
24.08.24	24,00	3.400	141,67	---	---	---	3:03	195,37	18,86
25.08.24	22,12	3.175	143,54	5:32	200,87	13,35	3:14	195,65	18,57
26.08.24	21,32	3.026	141,96	23:55	200,69	13,54	16:11	195,76	18,47
27.08.24	16,34	2.298	140,67	7:30	201,05	13,17	16:18	195,85	18,38
28.08.24	23,21	3.239	139,58	---	---	---	21:25	195,66	18,56
29.08.24	19,05	2.669	140,07	15:10	200,64	13,58	23:42	195,53	18,69
30.08.24	23,55	3.237	137,44	---	---	---	21:39	195,40	18,83
31.08.24	23,68	3.375	142,50	---	---	---	0:26	195,47	18,75
Σ	540,34	75.513							
Mittelwert	17,43	2.436	139,75		200,62	13,60		195,67	18,55
Minimum	0,00	0	131,89		200,22	13,09		195,32	18,11
Maximum	24,00	3.498	145,75		201,13	14,00		196,11	18,90

Meßpunkthöhe (MP): 214,22 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB14
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	24,00	2.226	92,75	---	---	---	0:19	197,62	22,50
02.08.24	24,00	2.231	92,96	---	---	---	23:21	197,71	22,42
03.08.24	24,00	2.238	93,25	---	---	---	18:34	197,77	22,35
04.08.24	3,36	306	90,95	23:58	200,69	19,43	0:14	197,85	22,27
05.08.24	8,65	807	93,35	5:54	200,84	19,28	19:51	198,32	21,80
06.08.24	13,32	1.244	93,42	7:30	201,08	19,04	23:46	198,24	21,88
07.08.24	15,04	1.392	92,55	5:52	200,69	19,43	23:38	198,22	21,90
08.08.24	9,21	815	88,51	16:49	200,83	19,30	2:21	198,25	21,87
09.08.24	3,55	328	92,39	3:05	200,98	19,14	11:57	198,53	21,59
10.08.24	0,00	0	---	19:56	201,03	19,09	---	---	---
11.08.24	0,00	0	---	22:59	201,12	19,01	---	---	---
12.08.24	3,08	290	94,26	3:28	201,34	18,78	23:22	198,61	21,51
13.08.24	21,79	2.002	91,89	11:33	201,15	18,97	11:57	197,77	22,36
14.08.24	22,17	2.046	92,29	8:08	200,75	19,37	23:03	197,97	22,15
15.08.24	24,00	2.222	92,58	---	---	---	18:59	197,77	22,35
16.08.24	24,00	2.285	95,21	---	---	---	0:00	198,25	21,87
17.08.24	24,00	2.279	94,96	---	---	---	23:38	198,34	21,78
18.08.24	23,26	2.194	94,32	---	---	---	17:42	198,25	21,87
19.08.24	23,45	2.167	92,42	---	---	---	21:05	197,89	22,23
20.08.24	23,18	2.160	93,17	---	---	---	22:27	197,85	22,27
21.08.24	23,39	2.177	93,08	---	---	---	21:12	197,77	22,36
22.08.24	24,00	2.214	92,25	---	---	---	23:32	197,78	22,34
23.08.24	22,84	2.100	91,94	22:59	200,02	20,11	19:25	197,66	22,46
24.08.24	10,36	954	92,10	10:59	200,48	19,64	2:52	197,81	22,31
25.08.24	6,37	593	93,04	5:32	200,89	19,23	2:02	198,28	21,84
26.08.24	11,48	1.081	94,13	5:11	200,76	19,36	21:33	198,32	21,80
27.08.24	19,93	1.873	93,96	12:00	200,70	19,43	23:58	198,24	21,88
28.08.24	15,44	1.426	92,37	8:55	200,67	19,46	21:09	198,21	21,91
29.08.24	15,40	1.411	91,60	9:03	200,67	19,46	23:27	198,13	21,99
30.08.24	16,88	1.561	92,50	8:17	200,41	19,72	17:59	197,90	22,23
31.08.24	8,32	770	92,60	23:57	200,60	19,53	0:17	198,00	22,13
Σ	488,46	45.392							
Mittelwert	15,76	1.464	92,93		200,78	19,34		198,04	22,08
Minimum	0,00	0	88,51		200,02	18,78		197,62	21,51
Maximum	24,00	2.285	95,21		201,34	20,11		198,61	22,50

Meßpunkthöhe (MP): 220,12 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB15
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb h	Menge m³	Leistung m³/h	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
01.08.24	24,00	2.362	98,42	---	---	---	21:30	197,61	23,77
02.08.24	24,00	2.374	98,92	---	---	---	23:43	197,57	23,82
03.08.24	24,00	2.395	99,79	---	---	---	0:00	197,60	23,79
04.08.24	3,60	365	101,30	23:59	203,23	18,15	0:16	197,86	23,52
05.08.24	8,94	935	104,58	9:01	203,44	17,94	19:51	199,50	21,88
06.08.24	13,24	1.372	103,59	7:28	203,68	17,70	23:51	199,46	21,92
07.08.24	15,34	1.578	102,90	5:48	203,22	18,17	23:51	199,30	22,08
08.08.24	9,55	950	99,51	16:54	203,39	18,00	14:21	196,00	25,38
09.08.24	3,67	376	102,54	8:40	203,67	17,71	12:02	199,86	21,52
10.08.24	0,00	0	---	20:18	203,81	17,57	---	---	---
11.08.24	0,00	0	---	23:40	203,95	17,43	---	---	---
12.08.24	3,18	326	102,38	3:28	204,13	17,26	23:50	199,80	21,58
13.08.24	21,47	2.110	98,26	11:29	203,40	17,98	11:56	198,79	22,59
14.08.24	22,29	2.199	98,68	8:06	202,77	18,61	23:22	198,33	23,05
15.08.24	24,00	2.362	98,42	---	---	---	19:13	197,91	23,47
16.08.24	24,00	2.580	107,50	---	---	---	0:00	198,33	23,05
17.08.24	24,00	2.561	106,71	---	---	---	23:56	198,64	22,74
18.08.24	23,32	2.436	104,46	---	---	---	20:27	198,52	22,86
19.08.24	23,50	2.311	98,32	---	---	---	21:22	198,03	23,35
20.08.24	19,53	1.972	100,97	12:29	203,29	18,09	0:00	198,08	23,31
21.08.24	23,45	2.462	105,01	---	---	---	0:45	198,58	22,80
22.08.24	24,00	2.413	100,54	---	---	---	23:46	198,19	23,19
23.08.24	22,90	2.222	97,02	23:00	202,12	19,27	19:43	197,79	23,60
24.08.24	10,54	1.069	101,39	10:53	202,98	18,40	3:02	198,33	23,05
25.08.24	6,66	697	104,61	12:05	203,48	17,90	2:06	199,44	21,95
26.08.24	11,83	1.264	106,82	5:21	203,51	17,87	23:26	199,44	21,94
27.08.24	20,10	2.149	106,92	11:56	203,29	18,09	0:00	199,44	21,94
28.08.24	15,79	1.615	102,31	8:49	203,23	18,15	21:19	199,28	22,10
29.08.24	15,71	1.548	98,57	8:57	203,11	18,27	18:35	198,83	22,55
30.08.24	17,04	1.728	101,40	8:30	203,14	18,24	21:38	198,83	22,56
31.08.24	8,62	896	103,91	23:48	203,20	18,18	0:17	199,05	22,34
Σ	488,28	49.627							
Mittelwert	15,75	1.601	101,64		203,33	18,05		198,56	22,82
Minimum	0,00	0	97,02		202,12	17,26		196,00	21,52
Maximum	24,00	2.580	107,50		204,13	19,27		199,86	25,38

Meßpunkthöhe (MP): 221,38 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB16
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	12,03	1.087	90,32	15:17	203,44	22,40	0:17	199,04	26,80
02.08.24	11,29	1.028	91,06	10:03	203,44	22,40	22:24	199,03	26,81
03.08.24	10,11	930	92,00	9:52	203,44	22,40	23:49	199,03	26,81
04.08.24	22,58	2.239	99,17	---	---	---	0:00	199,04	26,80
05.08.24	23,59	2.329	98,72	---	---	---	20:00	200,24	25,60
06.08.24	21,93	2.138	97,50	9:49	205,03	20,82	16:02	200,23	25,61
07.08.24	24,00	2.341	97,54	---	---	---	19:10	200,05	25,79
08.08.24	23,30	2.252	96,64	---	---	---	14:21	199,00	26,84
09.08.24	23,50	2.325	98,94	---	---	---	12:06	200,40	25,45
10.08.24	24,00	2.378	99,08	---	---	---	1:20	200,35	25,49
11.08.24	24,00	2.391	99,63	---	---	---	0:00	200,48	25,36
12.08.24	22,47	2.196	97,74	---	---	---	23:21	200,13	25,71
13.08.24	19,45	1.810	93,04	2:30	204,11	21,73	23:59	199,37	26,48
14.08.24	14,58	1.329	91,15	9:56	204,02	21,82	23:03	199,07	26,77
15.08.24	13,12	1.184	90,22	9:11	203,42	22,42	2:04	199,04	26,80
16.08.24	0,00	0	---	23:51	204,22	21,63	---	---	---
17.08.24	2,95	272	92,11	17:02	204,39	21,45	21:13	200,01	25,84
18.08.24	6,39	594	92,92	11:42	204,25	21,59	17:42	199,71	26,13
19.08.24	13,63	1.231	90,35	7:40	204,02	21,83	21:05	199,05	26,79
20.08.24	12,06	1.131	93,79	12:21	205,06	20,78	22:26	199,85	25,99
21.08.24	14,70	1.397	95,04	16:25	205,08	20,76	0:30	200,10	25,74
22.08.24	14,35	1.319	91,93	4:59	205,16	20,69	23:31	199,23	26,61
23.08.24	16,33	1.510	92,46	5:34	203,54	22,30	19:14	199,03	26,81
24.08.24	24,00	2.350	97,92	---	---	---	3:03	199,35	26,49
25.08.24	22,19	2.197	99,02	5:31	205,03	20,82	3:15	200,10	25,74
26.08.24	21,41	2.105	98,31	23:59	204,59	21,25	16:08	200,37	25,48
27.08.24	15,35	1.494	97,36	7:31	205,38	20,46	23:58	200,37	25,47
28.08.24	24,00	2.320	96,67	---	---	---	21:27	200,05	25,79
29.08.24	24,00	2.290	95,42	---	---	---	16:53	199,27	26,57
30.08.24	24,00	2.309	96,21	---	---	---	21:41	199,65	26,19
31.08.24	23,72	2.335	98,44	---	---	---	0:22	199,79	26,05
Σ	549,03	52.811							
Mittelwert	17,71	1.704	96,19		204,31	21,53		199,68	26,16
Minimum	0,00	0	90,22		203,42	20,46		199,00	25,36
Maximum	24,00	2.391	99,63		205,38	22,42		200,48	26,84

Meßpunkthöhe (MP): 225,84 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB17
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	24,00	2.466	102,75	---	---	---	21:28	193,56	37,86
02.08.24	24,00	2.473	103,04	---	---	---	23:39	193,53	37,89
03.08.24	23,44	2.421	103,27	---	---	---	0:00	193,54	37,87
04.08.24	0,00	0	---	23:52	205,08	26,33	---	---	---
05.08.24	0,00	0	---	7:04	205,30	26,12	---	---	---
06.08.24	2,61	261	100,00	7:27	205,52	25,89	---	---	---
07.08.24	0,67	67	99,26	6:18	205,07	26,35	---	---	---
08.08.24	0,00	0	---	16:42	205,30	26,12	---	---	---
09.08.24	3,36	345	102,75	6:49	205,45	25,97	22:15	196,26	35,15
10.08.24	5,88	597	101,47	20:05	205,31	26,10	1:11	196,08	35,34
11.08.24	3,62	372	102,79	10:24	205,43	25,98	12:00	196,41	35,00
12.08.24	10,07	1.033	102,60	4:52	205,68	25,74	23:42	194,77	36,65
13.08.24	20,01	2.037	101,80	11:55	204,91	26,50	4:49	194,57	36,85
14.08.24	24,00	2.435	101,46	---	---	---	23:18	193,77	37,64
15.08.24	24,00	2.439	101,63	---	---	---	19:15	193,51	37,90
16.08.24	24,00	2.607	108,63	---	---	---	0:00	194,14	37,28
17.08.24	24,00	2.583	107,63	---	---	---	23:54	194,58	36,83
18.08.24	24,00	2.539	105,79	---	---	---	20:49	194,37	37,05
19.08.24	24,00	2.441	101,71	---	---	---	21:26	193,73	37,69
20.08.24	14,21	1.459	102,67	12:31	205,40	26,01	0:00	193,76	37,66
21.08.24	0,00	0	---	16:30	205,80	25,62	---	---	---
22.08.24	16,99	1.730	101,81	5:07	205,91	25,51	23:53	193,97	37,44
23.08.24	20,61	2.067	100,31	23:59	203,72	27,69	19:46	193,58	37,84
24.08.24	0,00	0	---	22:33	204,84	26,58	---	---	---
25.08.24	0,00	0	---	5:44	205,56	25,86	---	---	---
26.08.24	1,78	188	105,35	5:25	205,31	26,10	22:56	195,70	35,72
27.08.24	0,99	101	101,59	7:21	205,77	25,65	---	---	---
28.08.24	2,00	206	103,09	8:55	205,10	26,32	23:59	196,12	35,29
29.08.24	7,56	735	97,24	8:56	204,87	26,55	16:40	195,28	36,13
30.08.24	2,12	208	98,32	8:50	204,88	26,53	13:57	196,31	35,11
31.08.24	0,00	0	---	9:29	204,99	26,42	---	---	---
Σ	327,93	33.810							
Mittelwert	10,58	1.091	103,10		205,23	26,18		194,64	36,77
Minimum	0,00	0	97,24		203,72	25,51		193,51	35,00
Maximum	24,00	2.607	108,63		205,91	27,69		196,41	37,90

Meßpunkthöhe (MP): 231,41 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB18
Monatsbericht vom August 2024

gedruckt am: 01.09.2024, 09:47 Uhr in Stadtallendorf

Tag	Förderdaten			Abotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
h	m³	m³/h							
01.08.24	11,51	988	85,82	15:19	211,69	20,36	21:09	204,00	28,06
02.08.24	10,65	925	86,87	10:05	211,86	20,20	23:15	204,10	27,95
03.08.24	9,57	841	87,83	9:58	211,84	20,21	23:59	204,39	27,66
04.08.24	22,34	2.066	92,49	---	---	---	6:54	203,40	28,65
05.08.24	23,44	2.161	92,21	---	---	---	23:23	203,52	28,53
06.08.24	21,44	1.956	91,23	9:50	211,12	20,93	0:13	203,55	28,50
07.08.24	24,00	2.186	91,08	---	---	---	23:56	203,54	28,52
08.08.24	23,26	2.099	90,25	---	---	---	3:41	203,46	28,59
09.08.24	23,42	2.151	91,85	---	---	---	23:45	203,48	28,58
10.08.24	24,00	2.196	91,50	---	---	---	1:52	203,39	28,67
11.08.24	24,00	2.209	92,04	---	---	---	0:52	203,45	28,61
12.08.24	22,28	2.009	90,17	---	---	---	0:00	203,60	28,46
13.08.24	18,75	1.646	87,79	5:51	210,91	21,15	23:52	203,64	28,41
14.08.24	14,08	1.213	86,14	10:15	211,74	20,32	0:48	203,58	28,47
15.08.24	12,77	1.090	85,33	23:59	211,43	20,63	18:42	203,69	28,36
16.08.24	0,00	0	---	23:27	212,75	19,31	---	---	---
17.08.24	2,70	238	88,18	17:24	212,93	19,13	---	---	---
18.08.24	5,87	523	89,14	11:42	212,58	19,48	17:38	205,76	26,30
19.08.24	13,11	1.133	86,44	8:06	212,21	19,85	20:59	204,24	27,82
20.08.24	11,19	1.006	89,92	12:25	212,41	19,65	22:23	204,29	27,77
21.08.24	14,18	1.292	91,12	5:08	212,15	19,91	13:20	204,61	27,45
22.08.24	13,70	1.199	87,52	8:29	212,45	19,60	23:27	204,30	27,75
23.08.24	15,80	1.383	87,52	5:39	211,21	20,84	22:57	203,49	28,56
24.08.24	24,00	2.189	91,21	---	---	---	5:15	203,29	28,76
25.08.24	22,02	2.033	92,31	5:34	210,86	21,19	3:03	203,55	28,50
26.08.24	23,70	2.211	93,30	---	---	---	23:26	203,20	28,86
27.08.24	24,00	2.223	92,63	---	---	---	0:00	203,20	28,86
28.08.24	24,00	2.181	90,88	---	---	---	21:43	203,48	28,58
29.08.24	24,00	2.154	89,75	---	---	---	19:13	203,14	28,92
30.08.24	24,00	2.170	90,42	---	---	---	0:01	203,23	28,82
31.08.24	23,64	2.165	91,59	---	---	---	2:12	203,31	28,75
Σ	551,41	49.836							
Mittelwert	17,79	1.608	90,38		211,88	20,17		203,72	28,33
Minimum	0,00	0	85,33		210,86	19,13		203,14	26,30
Maximum	24,00	2.223	93,30		212,93	21,19		205,76	28,92

Meßpunkthöhe (MP): 232,05 m üNN