

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB20
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	1.178	49,08	---	---	---	13:11	193,06	16,70
02.10.24	24,00	1.186	49,42	---	---	---	22:42	193,00	16,76
03.10.24	24,00	1.195	49,79	---	---	---	1:25	193,02	16,74
04.10.24	24,00	1.193	49,71	---	---	---	11:08	193,11	16,65
05.10.24	24,00	1.196	49,83	---	---	---	0:00	193,14	16,62
06.10.24	24,00	1.194	49,75	---	---	---	1:56	193,15	16,61
07.10.24	24,00	1.187	49,46	---	---	---	23:22	193,11	16,65
08.10.24	21,16	1.042	49,24	12:55	194,95	14,81	8:25	193,02	16,74
09.10.24	24,00	1.188	49,50	---	---	---	0:42	193,02	16,74
10.10.24	24,00	1.195	49,79	---	---	---	15:52	193,05	16,71
11.10.24	24,00	1.205	50,21	---	---	---	0:00	193,27	16,49
12.10.24	24,00	1.216	50,67	---	---	---	1:48	193,44	16,32
13.10.24	24,00	1.226	51,08	---	---	---	0:52	193,69	16,07
14.10.24	24,00	1.218	50,75	---	---	---	23:42	193,72	16,04
15.10.24	22,64	1.136	50,17	11:32	195,14	14,62	14:17	193,51	16,25
16.10.24	24,00	1.192	49,67	---	---	---	23:45	193,19	16,58
17.10.24	24,00	1.177	49,04	---	---	---	23:45	192,96	16,80
18.10.24	24,00	1.175	48,96	---	---	---	22:37	192,86	16,90
19.10.24	24,00	1.188	49,50	---	---	---	11:28	192,84	16,93
20.10.24	24,00	1.217	50,71	---	---	---	0:00	193,20	16,56
21.10.24	24,00	1.212	50,50	---	---	---	21:19	193,33	16,43
22.10.24	22,74	1.154	50,75	13:31	194,92	14,84	0:00	193,39	16,37
23.10.24	24,00	1.213	50,54	---	---	---	23:20	193,60	16,16
24.10.24	24,00	1.199	49,96	---	---	---	23:45	193,30	16,46
25.10.24	24,00	1.191	49,63	---	---	---	23:59	193,20	16,56
26.10.24	24,00	1.199	49,96	---	---	---	0:00	193,20	16,56
27.10.24	25,00	1.251	50,04	---	---	---	23:59	193,25	16,51
28.10.24	24,00	1.190	49,58	---	---	---	23:14	193,13	16,63
29.10.24	24,00	1.196	49,83	---	---	---	2:24	193,11	16,65
30.10.24	24,00	1.236	51,50	---	---	---	3:43	193,35	16,42
31.10.24	24,00	1.235	51,46	---	---	---	0:00	194,27	15,49
Σ	739,54	36.980							
Mittelwert	23,86	1.193	50,00		195,00	14,76		193,24	16,52
Minimum	21,16	1.042	48,96		194,92	14,62		192,84	15,49
Maximum	25,00	1.251	51,50		195,14	14,84		194,27	16,93

Meßpunkthöhe (MP): 209,76 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB22
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	5.562	231,75	---	---	---	11:34	191,35	16,48
02.10.24	24,00	5.601	233,38	---	---	---	0:29	191,56	16,26
03.10.24	24,00	5.654	235,58	---	---	---	0:54	191,79	16,03
04.10.24	24,00	5.641	235,04	---	---	---	9:55	191,86	15,96
05.10.24	24,00	5.655	235,63	---	---	---	20:41	191,88	15,94
06.10.24	24,00	5.646	235,25	---	---	---	1:37	191,95	15,87
07.10.24	24,00	5.613	233,88	---	---	---	22:15	191,79	16,03
08.10.24	23,11	5.347	231,35	---	---	---	23:22	191,48	16,34
09.10.24	24,00	5.614	233,92	---	---	---	0:00	191,56	16,26
10.10.24	16,43	3.835	233,43	23:58	198,63	9,19	14:47	191,72	16,10
11.10.24	1,13	248	219,42	6:57	199,07	8,75	---	---	---
12.10.24	0,00	0	---	22:44	199,36	8,46	---	---	---
13.10.24	0,00	0	---	11:51	199,79	8,04	---	---	---
14.10.24	0,00	0	---	7:23	199,82	8,00	---	---	---
15.10.24	4,82	1.091	226,24	8:27	199,76	8,07	11:45	191,96	15,86
16.10.24	14,15	3.287	232,32	10:05	199,26	8,56	23:41	191,65	16,17
17.10.24	24,00	5.542	230,92	---	---	---	23:52	191,38	16,44
18.10.24	24,00	5.537	230,71	---	---	---	20:55	191,30	16,52
19.10.24	15,03	3.468	230,70	23:49	198,49	9,33	0:54	191,30	16,52
20.10.24	0,00	0	---	17:22	199,35	8,47	---	---	---
21.10.24	3,97	916	230,73	5:36	199,49	8,33	20:35	191,64	16,19
22.10.24	3,32	772	232,84	22:05	199,51	8,31	12:59	191,69	16,13
23.10.24	0,63	141	224,01	11:09	199,76	8,07	---	---	---
24.10.24	12,43	2.924	235,26	5:42	199,13	8,69	22:48	192,03	15,79
25.10.24	24,00	5.631	234,63	---	---	---	16:50	191,90	15,93
26.10.24	24,00	5.670	236,25	---	---	---	21:48	192,15	15,67
27.10.24	24,54	5.808	236,66	---	---	---	19:25	192,05	15,77
28.10.24	24,00	5.619	234,13	---	---	---	18:18	191,70	16,12
29.10.24	5,69	1.285	225,64	6:06	198,59	9,23	11:50	191,19	16,64
30.10.24	0,00	0	---	23:55	201,37	6,45	---	---	---
31.10.24	0,00	0	---	8:33	201,68	6,14	---	---	---
Σ	437,25	102.107							
Mittelwert	14,10	3.294	233,52		199,56	8,26		191,69	16,13
Minimum	0,00	0	219,42		198,49	6,14		191,19	15,67
Maximum	24,54	5.808	236,66		201,68	9,33		192,15	16,64

Meßpunkthöhe (MP): 207,82 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB23
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	2,82	380	134,80	5:40	193,29	19,55	11:30	188,53	24,31
02.10.24	0,00	0	---	9:36	192,99	19,84	---	---	---
03.10.24	0,00	0	---	14:22	193,45	19,38	---	---	---
04.10.24	0,57	76	132,30	7:28	193,36	19,47	---	---	---
05.10.24	0,00	0	---	11:34	193,48	19,35	---	---	---
06.10.24	0,00	0	---	10:39	193,47	19,37	---	---	---
07.10.24	0,00	0	---	5:41	193,35	19,49	---	---	---
08.10.24	1,71	234	137,11	8:58	193,73	19,11	10:42	189,26	23,57
09.10.24	0,00	0	---	23:59	193,10	19,73	---	---	---
10.10.24	7,56	1.094	144,79	10:06	193,44	19,40	19:07	189,17	23,67
11.10.24	24,00	3.443	143,46	---	---	---	13:09	189,03	23,81
12.10.24	24,00	3.476	144,83	---	---	---	1:33	189,58	23,25
13.10.24	24,00	3.508	146,17	---	---	---	0:17	190,19	22,64
14.10.24	24,00	3.482	145,08	---	---	---	23:12	190,03	22,81
15.10.24	22,78	3.244	142,39	---	---	---	13:44	188,80	24,03
16.10.24	10,67	1.520	142,47	11:06	193,53	19,30	6:33	189,66	23,18
17.10.24	0,00	0	---	1:17	192,24	20,59	---	---	---
18.10.24	0,00	0	---	10:22	191,97	20,87	---	---	---
19.10.24	8,95	1.288	143,89	12:55	191,97	20,87	16:10	188,75	24,08
20.10.24	24,00	3.480	145,00	---	---	---	0:47	189,44	23,39
21.10.24	24,00	3.460	144,17	---	---	---	20:37	188,54	24,29
22.10.24	23,72	3.432	144,71	---	---	---	13:02	188,68	24,16
23.10.24	24,00	3.467	144,46	---	---	---	15:03	189,64	23,19
24.10.24	16,56	2.342	141,44	13:22	193,79	19,05	22:41	189,61	23,22
25.10.24	7,08	979	138,35	8:42	193,73	19,11	16:45	189,47	23,36
26.10.24	3,11	429	137,79	11:43	193,65	19,18	---	---	---
27.10.24	3,78	523	138,49	5:41	194,30	18,54	19:20	189,66	23,18
28.10.24	8,07	1.125	139,42	8:39	193,76	19,08	21:57	189,26	23,57
29.10.24	21,73	3.082	141,86	2:17	193,24	19,59	11:49	188,40	24,43
30.10.24	3,78	533	140,87	23:44	196,44	16,40	0:41	189,35	23,48
31.10.24	0,00	0	---	7:40	196,81	16,03	---	---	---
Σ	310,88	44.597							
Mittelwert	10,03	1.439	143,45		193,59	19,24		189,25	23,58
Minimum	0,00	0	132,30		191,97	16,03		188,40	22,64
Maximum	24,00	3.508	146,17		196,81	20,87		190,19	24,43

Meßpunkthöhe (MP): 212,83 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB24
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	12,93	2.390	184,88	5:37	193,28	16,84	18:59	177,28	32,84
02.10.24	11,03	2.057	186,41	9:34	192,93	17,19	0:19	177,19	32,93
03.10.24	5,13	947	184,78	11:06	193,55	16,56	0:41	177,69	32,42
04.10.24	5,97	1.112	186,36	7:12	193,45	16,67	9:43	177,72	32,39
05.10.24	5,23	994	190,09	10:39	193,57	16,55	20:34	177,74	32,38
06.10.24	6,63	1.241	187,16	10:36	193,59	16,53	1:21	177,94	32,18
07.10.24	9,54	1.772	185,79	5:51	193,40	16,71	14:50	177,66	32,45
08.10.24	15,71	2.927	186,27	9:35	193,48	16,64	18:35	177,25	32,87
09.10.24	9,06	1.691	186,74	23:57	193,11	17,00	15:46	177,63	32,49
10.10.24	10,39	1.963	188,85	8:34	193,52	16,59	19:05	177,08	33,03
11.10.24	14,15	2.708	191,34	6:53	193,43	16,68	13:48	177,29	32,82
12.10.24	10,34	1.984	191,83	11:01	193,81	16,30	1:31	177,52	32,59
13.10.24	4,64	879	189,61	11:53	194,45	15,66	0:15	178,21	31,91
14.10.24	12,09	2.330	192,69	7:18	194,47	15,65	23:10	177,98	32,13
15.10.24	17,72	3.350	189,09	8:30	194,09	16,03	23:25	177,32	32,79
16.10.24	18,25	3.459	189,54	10:00	193,71	16,41	23:26	177,16	32,96
17.10.24	24,00	4.502	187,58	---	---	---	14:44	177,00	33,11
18.10.24	24,00	4.495	187,29	---	---	---	0:00	177,00	33,11
19.10.24	21,45	4.048	188,75	23:40	192,67	17,45	2:51	177,00	33,11
20.10.24	8,40	1.610	191,69	17:15	193,84	16,27	0:45	177,45	32,67
21.10.24	12,65	2.420	191,24	5:31	194,04	16,07	20:54	177,08	33,03
22.10.24	11,06	2.122	191,93	21:40	194,26	15,86	13:05	177,37	32,74
23.10.24	14,45	2.774	191,98	10:31	194,47	15,65	23:55	177,57	32,55
24.10.24	7,76	1.470	189,49	13:37	193,83	16,29	1:51	177,46	32,65
25.10.24	0,00	0	---	6:15	193,92	16,19	---	---	---
26.10.24	0,00	0	---	4:10	193,77	16,35	---	---	---
27.10.24	0,00	0	---	8:30	194,42	15,69	---	---	---
28.10.24	0,49	89	180,91	8:34	194,00	16,12	---	---	---
29.10.24	21,00	4.014	191,17	2:26	193,31	16,80	19:43	177,00	33,11
30.10.24	3,80	720	189,40	23:53	196,00	14,12	1:30	177,00	33,11
31.10.24	0,00	0	---	7:05	196,65	13,46	---	---	---
Σ	317,86	60.068							
Mittelwert	10,25	1.938	188,98		193,89	16,22		177,41	32,70
Minimum	0,00	0	180,91		192,67	13,46		177,00	31,91
Maximum	24,00	4.502	192,69		196,65	17,45		178,21	33,11

Meßpunkthöhe (MP): 210,11 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB25
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	2.873	119,71	---	---	---	19:04	183,23	31,54
02.10.24	23,90	2.873	120,22	---	---	---	0:25	183,14	31,63
03.10.24	22,21	2.692	121,19	---	---	---	0:53	183,34	31,43
04.10.24	23,23	2.812	121,04	---	---	---	15:56	183,54	31,24
05.10.24	23,74	2.880	121,32	---	---	---	20:41	183,49	31,28
06.10.24	22,98	2.782	121,07	---	---	---	1:28	183,54	31,24
07.10.24	23,70	2.855	120,48	---	---	---	22:15	183,39	31,39
08.10.24	22,70	2.706	119,22	9:04	193,40	21,37	23:21	183,02	31,75
09.10.24	23,62	2.845	120,42	---	---	---	0:00	183,13	31,65
10.10.24	23,10	2.797	121,06	---	---	---	19:07	183,25	31,53
11.10.24	24,00	2.928	122,00	---	---	---	13:56	183,65	31,13
12.10.24	24,00	2.956	123,17	---	---	---	1:39	183,83	30,95
13.10.24	22,96	2.850	124,13	---	---	---	0:24	184,39	30,38
14.10.24	24,00	2.961	123,38	---	---	---	23:21	184,32	30,46
15.10.24	23,13	2.807	121,37	---	---	---	23:29	183,78	30,99
16.10.24	20,00	2.404	120,20	12:32	193,97	20,81	23:12	183,78	30,99
17.10.24	16,14	1.912	118,46	5:50	193,20	21,57	23:42	183,26	31,51
18.10.24	14,87	1.770	119,00	9:40	192,99	21,79	19:53	183,28	31,50
19.10.24	14,19	1.708	120,39	12:34	193,17	21,60	22:07	183,33	31,45
20.10.24	24,00	2.957	123,21	---	---	---	0:53	183,60	31,17
21.10.24	23,76	2.921	122,94	---	---	---	22:51	183,89	30,89
22.10.24	21,09	2.599	123,21	---	---	---	3:53	183,92	30,85
23.10.24	23,54	2.894	122,91	---	---	---	23:52	184,26	30,52
24.10.24	24,00	2.918	121,58	---	---	---	1:58	184,01	30,76
25.10.24	23,06	2.781	120,58	---	---	---	22:53	184,01	30,76
26.10.24	22,52	2.748	122,01	---	---	---	22:29	184,13	30,64
27.10.24	19,76	2.390	120,97	6:19	194,65	20,12	0:00	184,15	30,63
28.10.24	21,63	2.617	120,99	---	---	---	23:00	183,84	30,93
29.10.24	15,81	1.901	120,22	5:48	194,12	20,65	13:16	183,81	30,96
30.10.24	19,33	2.423	125,32	8:35	194,84	19,94	0:40	183,87	30,90
31.10.24	20,14	2.496	123,95	7:01	196,45	18,32	18:31	185,24	29,54
Σ	675,13	82.056							
Mittelwert	21,78	2.647	121,54		194,09	20,68		183,72	31,05
Minimum	14,19	1.708	118,46		192,99	18,32		183,02	29,54
Maximum	24,00	2.961	125,32		196,45	21,79		185,24	31,75

Meßpunkthöhe (MP): 214,77 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB26
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	1.354	56,42	---	---	---	20:13	188,32	24,96
02.10.24	23,91	1.363	57,01	---	---	---	1:14	188,24	25,04
03.10.24	22,26	1.291	58,01	---	---	---	1:45	188,26	25,02
04.10.24	23,24	1.342	57,74	---	---	---	5:10	188,42	24,86
05.10.24	23,75	1.376	57,93	---	---	---	21:40	188,44	24,84
06.10.24	22,99	1.330	57,85	---	---	---	2:54	188,42	24,86
07.10.24	23,71	1.355	57,15	---	---	---	22:43	188,37	24,91
08.10.24	22,71	1.272	56,01	9:05	193,98	19,30	23:56	188,06	25,22
09.10.24	23,64	1.350	57,10	---	---	---	0:00	188,06	25,22
10.10.24	23,13	1.342	58,01	---	---	---	15:50	188,34	24,94
11.10.24	24,00	1.435	59,79	---	---	---	0:00	189,45	23,83
12.10.24	24,00	1.463	60,96	---	---	---	1:53	189,92	23,36
13.10.24	23,01	1.427	62,03	---	---	---	0:49	190,46	22,82
14.10.24	24,00	1.471	61,29	---	---	---	23:57	190,53	22,75
15.10.24	23,04	1.367	59,34	---	---	---	13:58	189,84	23,44
16.10.24	20,06	1.170	58,32	12:31	195,25	18,03	23:21	189,09	24,19
17.10.24	16,24	910	56,04	5:48	194,12	19,16	23:42	188,44	24,84
18.10.24	14,98	841	56,14	9:36	193,76	19,52	19:55	188,44	24,84
19.10.24	14,27	831	58,22	12:29	193,93	19,35	0:29	188,69	24,59
20.10.24	24,00	1.463	60,96	---	---	---	0:50	189,50	23,78
21.10.24	23,78	1.449	60,92	---	---	---	1:12	190,29	22,99
22.10.24	21,17	1.304	61,59	---	---	---	3:50	190,36	22,92
23.10.24	23,56	1.437	60,99	---	---	---	23:54	190,60	22,68
24.10.24	24,00	1.415	58,96	---	---	---	23:55	189,16	24,12
25.10.24	23,07	1.322	57,30	---	---	---	23:59	188,79	24,49
26.10.24	22,57	1.317	58,35	---	---	---	9:16	188,88	24,40
27.10.24	19,82	1.150	58,01	6:15	195,08	18,20	0:23	188,82	24,46
28.10.24	21,72	1.247	57,42	---	---	---	22:56	188,71	24,57
29.10.24	15,75	916	58,15	9:14	195,85	17,43	2:17	188,62	24,66
30.10.24	19,63	1.229	62,60	4:14	196,06	17,22	0:41	190,00	23,28
31.10.24	20,16	1.212	60,13	7:00	197,34	15,94	18:06	189,54	23,74
Σ	676,18	39.751							
Mittelwert	21,81	1.282	58,79		195,04	18,24		189,07	24,21
Minimum	14,27	831	56,01		193,76	15,94		188,06	22,68
Maximum	24,00	1.471	62,60		197,34	19,52		190,60	25,22

Meßpunkthöhe (MP): 213,28 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB27
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	2.604	108,50	---	---	---	20:07	193,51	23,29
02.10.24	24,00	2.625	109,38	---	---	---	22:46	193,42	23,38
03.10.24	24,00	2.654	110,58	---	---	---	6:19	193,30	23,50
04.10.24	24,00	2.645	110,21	---	---	---	5:11	193,40	23,40
05.10.24	24,00	2.651	110,46	---	---	---	10:09	193,42	23,38
06.10.24	24,00	2.646	110,25	---	---	---	7:17	193,40	23,40
07.10.24	24,00	2.617	109,04	---	---	---	2:55	193,39	23,41
08.10.24	23,09	2.487	107,72	---	---	---	23:55	193,29	23,51
09.10.24	24,00	2.628	109,50	---	---	---	1:23	193,26	23,54
10.10.24	16,39	1.790	109,19	23:45	201,24	15,56	4:53	193,36	23,44
11.10.24	1,07	113	105,44	23:44	201,66	15,14	---	---	---
12.10.24	0,00	0	---	23:23	202,06	14,74	---	---	---
13.10.24	0,00	0	---	12:14	202,31	14,49	---	---	---
14.10.24	0,00	0	---	7:42	202,36	14,44	---	---	---
15.10.24	3,94	417	105,87	9:08	202,39	14,41	11:45	195,29	21,51
16.10.24	14,12	1.537	108,83	10:00	201,99	14,81	23:41	194,04	22,76
17.10.24	24,00	2.591	107,96	---	---	---	23:53	193,61	23,19
18.10.24	24,00	2.587	107,79	---	---	---	20:13	193,56	23,24
19.10.24	15,00	1.620	108,01	23:50	201,24	15,56	0:48	193,59	23,21
20.10.24	0,00	0	---	18:20	201,93	14,87	---	---	---
21.10.24	0,00	0	---	6:39	202,06	14,74	---	---	---
22.10.24	0,00	0	---	---	---	---	---	---	---
23.10.24	0,00	0	---	13:54	202,55	14,25	---	---	---
24.10.24	12,44	1.384	111,28	6:49	202,14	14,66	23:55	194,02	22,78
25.10.24	24,00	2.651	110,46	---	---	---	23:59	193,62	23,18
26.10.24	24,00	2.666	111,08	---	---	---	0:14	193,61	23,19
27.10.24	24,52	2.733	111,47	---	---	---	0:26	193,61	23,19
28.10.24	24,00	2.643	110,13	---	---	---	23:23	193,56	23,24
29.10.24	4,82	511	106,05	9:18	201,79	15,01	2:18	193,44	23,36
30.10.24	0,20	24	122,03	23:41	202,24	14,56	---	---	---
31.10.24	13,47	1.489	110,57	7:11	202,53	14,27	17:48	194,34	22,46
Σ	441,05	48.313							
Mittelwert	14,23	1.558	109,54		202,03	14,77		193,64	23,16
Minimum	0,00	0	105,44		201,24	14,25		193,26	21,51
Maximum	24,52	2.733	122,03		202,55	15,56		195,29	23,54

Meßpunkthöhe (MP): 216,80 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB28
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	24,00	4.361	181,71	---	---	---	20:23	179,78	41,37
02.10.24	24,00	4.427	184,46	---	---	---	22:46	179,59	41,56
03.10.24	24,00	4.536	189,00	---	---	---	6:21	179,19	41,96
04.10.24	24,00	4.509	187,88	---	---	---	5:20	179,24	41,91
05.10.24	24,00	4.526	188,58	---	---	---	10:10	179,26	41,89
06.10.24	24,00	4.508	187,83	---	---	---	7:35	179,26	41,89
07.10.24	24,00	4.386	182,75	---	---	---	2:57	179,21	41,94
08.10.24	23,17	4.123	177,98	---	---	---	8:04	178,70	42,45
09.10.24	24,00	4.444	185,17	---	---	---	22:29	179,14	42,01
10.10.24	16,43	3.038	184,85	23:52	197,15	24,00	5:18	179,16	41,99
11.10.24	1,24	210	169,43	23:29	197,72	23,43	---	---	---
12.10.24	0,00	0	---	22:55	198,23	22,92	---	---	---
13.10.24	0,00	0	---	11:17	198,51	22,64	---	---	---
14.10.24	0,00	0	---	7:38	198,61	22,54	---	---	---
15.10.24	4,46	775	173,93	9:06	198,56	22,59	12:01	181,12	40,03
16.10.24	14,24	2.566	180,19	9:44	198,16	22,99	23:50	181,01	40,14
17.10.24	24,00	4.266	177,75	---	---	---	23:53	180,58	40,57
18.10.24	24,00	4.255	177,29	---	---	---	20:41	180,44	40,71
19.10.24	15,04	2.682	178,28	23:55	197,19	23,96	0:49	180,46	40,69
20.10.24	0,00	0	---	21:29	198,06	23,09	---	---	---
21.10.24	0,00	0	---	5:49	198,22	22,93	---	---	---
22.10.24	0,00	0	---	---	---	---	---	---	---
23.10.24	0,73	133	182,96	13:47	198,77	22,38	---	---	---
24.10.24	12,48	2.395	191,89	6:09	198,32	22,83	23:56	180,29	40,86
25.10.24	24,00	4.558	189,92	---	---	---	5:35	179,69	41,46
26.10.24	24,00	4.597	191,54	---	---	---	1:46	179,52	41,63
27.10.24	24,60	4.728	192,18	---	---	---	5:13	179,09	42,06
28.10.24	24,00	4.526	188,58	---	---	---	0:10	179,45	41,70
29.10.24	6,93	1.261	181,84	9:16	197,66	23,49	2:23	179,16	41,99
30.10.24	0,00	0	---	23:05	198,29	22,86	---	---	---
31.10.24	13,70	2.543	185,68	7:27	198,48	22,67	18:02	180,56	40,59
Σ	445,02	82.353							
Mittelwert	14,36	2.657	185,05		198,13	23,02		179,72	41,43
Minimum	0,00	0	169,43		197,15	22,38		178,70	40,03
Maximum	24,60	4.728	192,18		198,77	24,00		181,12	42,45

Meßpunkthöhe (MP): 221,15 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB29
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	0,00	0	---	---	---	---	---	---	---
02.10.24	0,00	0	---	18:43	188,02	39,51	---	---	---
03.10.24	0,00	0	---	20:27	188,02	39,51	---	---	---
04.10.24	0,00	0	---	9:16	188,02	39,51	---	---	---
05.10.24	0,00	0	---	9:40	188,02	39,51	---	---	---
06.10.24	0,00	0	---	13:08	188,02	39,51	---	---	---
07.10.24	0,00	0	---	21:59	188,02	39,51	---	---	---
08.10.24	0,00	0	---	11:35	188,02	39,51	---	---	---
09.10.24	0,00	0	---	20:36	188,02	39,51	---	---	---
10.10.24	0,00	0	---	4:13	188,02	39,51	---	---	---
11.10.24	0,00	0	---	0:22	188,02	39,51	---	---	---
12.10.24	0,00	0	---	2:45	188,02	39,51	---	---	---
13.10.24	0,00	0	---	3:35	188,02	39,51	---	---	---
14.10.24	0,00	0	---	18:44	188,02	39,51	---	---	---
15.10.24	0,00	0	---	4:57	188,02	39,51	---	---	---
16.10.24	0,00	0	---	---	---	---	---	---	---
17.10.24	0,00	0	---	17:07	188,02	39,51	---	---	---
18.10.24	0,00	0	---	14:43	188,02	39,51	---	---	---
19.10.24	0,00	0	---	16:48	188,02	39,51	---	---	---
20.10.24	0,00	0	---	4:33	188,02	39,51	---	---	---
21.10.24	0,00	0	---	15:23	188,02	39,51	---	---	---
22.10.24	0,00	0	---	2:36	188,02	39,51	---	---	---
23.10.24	0,00	0	---	10:29	188,02	39,51	---	---	---
24.10.24	0,00	0	---	---	---	---	---	---	---
25.10.24	0,00	0	---	0:00	188,01	39,51	---	---	---
26.10.24	0,00	0	---	7:35	188,02	39,51	---	---	---
27.10.24	0,00	0	---	8:22	188,02	39,51	---	---	---
28.10.24	0,00	0	---	---	---	---	---	---	---
29.10.24	0,00	0	---	---	---	---	---	---	---
30.10.24	0,00	0	---	---	---	---	---	---	---
31.10.24	0,00	0	---	5:37	188,02	39,51	---	---	---
Σ	0,00	0							
Mittelwert	0,00	0	---		188,01	39,51		---	---
Minimum	0,00	0	---		188,01	39,51		---	---
Maximum	0,00	0	---		188,02	39,51		---	---

Meßpunkthöhe (MP): 227,52 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB31
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt Uhr	m üNN	m uMP	Zeitpunkt Uhr	m üNN	m uMP
	h	m³	m³/h						
01.10.24	12,51	910	72,76	5:36	200,35	35,12	23:57	189,12	46,34
02.10.24	9,77	720	73,67	9:37	199,92	35,55	0:14	189,11	46,35
03.10.24	4,36	316	72,42	21:04	200,23	35,23	0:32	189,55	45,92
04.10.24	5,23	377	72,10	7:43	200,17	35,29	15:45	190,45	45,01
05.10.24	4,48	333	74,35	12:13	200,27	35,19	20:29	189,25	46,22
06.10.24	5,52	406	73,52	16:36	200,28	35,18	23:01	189,57	45,89
07.10.24	14,43	1.040	72,07	5:50	200,20	35,26	16:33	189,06	46,40
08.10.24	19,32	1.330	68,85	10:20	199,73	35,73	23:04	188,81	46,65
09.10.24	7,96	588	73,84	23:56	199,92	35,55	15:38	189,06	46,40
10.10.24	9,67	693	71,65	23:58	200,61	34,85	14:21	189,05	46,41
11.10.24	12,96	890	68,69	6:58	201,33	34,13	13:07	190,83	44,64
12.10.24	9,07	643	70,87	22:45	201,96	33,50	14:26	191,25	44,22
13.10.24	4,02	283	70,33	11:41	202,42	33,04	13:51	192,05	43,41
14.10.24	11,01	757	68,74	7:17	202,54	32,92	22:53	192,32	43,14
15.10.24	16,22	1.084	66,84	9:17	202,31	33,15	11:44	191,18	44,28
16.10.24	17,59	1.247	70,88	10:09	201,96	33,50	21:54	189,83	45,63
17.10.24	24,00	1.683	70,13	---	---	---	22:58	189,25	46,21
18.10.24	24,00	1.676	69,83	---	---	---	20:33	188,92	46,54
19.10.24	21,08	1.453	68,94	23:43	200,53	34,93	3:38	189,02	46,45
20.10.24	7,31	517	70,73	17:24	201,79	33,67	3:00	190,89	44,57
21.10.24	1,70	111	65,27	5:27	202,04	33,42	6:41	192,63	42,83
22.10.24	0,00	0	---	---	---	---	---	---	---
23.10.24	10,20	700	68,65	13:35	202,85	32,61	15:03	191,84	43,63
24.10.24	7,33	467	63,73	5:42	202,01	33,46	1:28	192,02	43,44
25.10.24	0,00	0	---	0:00	201,08	34,38	---	---	---
26.10.24	0,00	0	---	15:17	200,83	34,64	---	---	---
27.10.24	0,00	0	---	11:23	201,07	34,39	---	---	---
28.10.24	0,31	22	69,84	6:36	200,96	34,50	---	---	---
29.10.24	20,55	1.274	61,99	2:44	200,54	34,92	11:43	190,13	45,34
30.10.24	24,00	1.373	57,21	---	---	---	1:07	192,19	43,27
31.10.24	23,88	1.495	62,60	---	---	---	18:00	189,96	45,50
Σ	328,49	22.388							
Mittelwert	10,60	722	68,15		201,07	34,39		190,28	45,18
Minimum	0,00	0	57,21		199,73	32,61		188,81	42,83
Maximum	24,00	1.683	74,35		202,85	35,73		192,63	46,65

Meßpunkthöhe (MP): 235,46 m üNN

ZMW Gießen
Wasserwerk Stadtallendorf
Brunnenbericht WAB32
Monatsbericht vom Oktober 2024
gedruckt am: 03.11.2024, 14:49 Uhr in Stadtallendorf

Tag	Förderdaten			Ablotung Wasserspiegel					
	Betrieb	Menge	Leistung	1) Ruhe			2) Betrieb		
				Zeitpunkt			Zeitpunkt		
	h	m³	m³/h	Uhr	m üNN	m uMP	Uhr	m üNN	m uMP
01.10.24	3,63	598	164,80	3:13	196,67	48,15	12:36	192,83	51,99
02.10.24	0,00	0	---	14:08	196,61	48,22	---	---	---
03.10.24	0,00	0	---	17:20	196,71	48,12	---	---	---
04.10.24	0,70	116	166,57	6:29	196,71	48,11	---	---	---
05.10.24	0,00	0	---	19:23	196,78	48,04	---	---	---
06.10.24	0,00	0	---	17:33	196,87	47,96	---	---	---
07.10.24	0,00	0	---	6:47	196,87	47,96	---	---	---
08.10.24	2,00	340	169,62	10:24	196,81	48,02	12:03	193,51	51,31
09.10.24	0,00	0	---	23:12	196,88	47,94	---	---	---
10.10.24	7,63	1.287	168,63	3:08	196,93	47,90	22:50	192,91	51,91
11.10.24	24,00	3.982	165,92	---	---	---	19:19	192,79	52,04
12.10.24	24,00	3.951	164,63	---	---	---	0:11	192,83	51,99
13.10.24	24,00	3.976	165,67	---	---	---	0:37	193,08	51,75
14.10.24	24,00	3.966	165,25	---	---	---	22:50	193,06	51,76
15.10.24	22,01	3.651	165,85	9:43	196,46	48,36	23:42	192,80	52,02
16.10.24	10,84	1.780	164,14	16:20	196,77	48,05	0:38	192,79	52,04
17.10.24	0,00	0	---	6:25	196,74	48,08	---	---	---
18.10.24	0,00	0	---	10:03	196,68	48,14	---	---	---
19.10.24	9,03	1.508	167,05	7:35	196,73	48,09	23:57	192,79	52,04
20.10.24	24,00	3.960	165,00	---	---	---	0:39	192,77	52,05
21.10.24	24,00	3.952	164,67	---	---	---	1:26	192,94	51,88
22.10.24	22,43	3.711	165,43	10:59	196,47	48,35	3:45	193,02	51,81
23.10.24	24,00	3.950	164,58	---	---	---	20:29	193,00	51,82
24.10.24	17,10	2.793	163,31	13:31	196,45	48,37	1:28	193,02	51,81
25.10.24	7,89	1.305	165,39	9:01	196,74	48,08	16:48	193,08	51,75
26.10.24	3,61	608	168,60	12:06	196,74	48,08	---	---	---
27.10.24	4,15	694	167,35	8:45	196,97	47,86	19:22	193,32	51,50
28.10.24	8,65	1.447	167,23	7:55	196,85	47,97	18:16	192,94	51,88
29.10.24	21,97	3.628	165,11	2:16	196,34	48,48	20:28	192,77	52,05
30.10.24	24,00	3.994	166,42	---	---	---	1:06	192,76	52,06
31.10.24	24,00	3.959	164,96	---	---	---	19:12	192,78	52,04
Σ	357,65	59.156							
Mittelwert	11,54	1.908	165,40		196,72	48,10		192,94	51,88
Minimum	0,00	0	163,31		196,34	47,86		192,76	51,31
Maximum	24,00	3.994	169,62		196,97	48,48		193,51	52,06

Meßpunkthöhe (MP): 244,82 m üNN